



# State of Maryland Department of Health and Mental Hygiene

PUBLIC SWIMMING POOL and SPA

OPERATING RECORD SHEET FOR FECAL ACCIDENT AND CLEANUP

Facility Name \_\_\_\_\_

**Follow Maryland Department of Health & Mental Hygiene cleanup and disinfecting procedures.**

Record test readings every 15 feet around the perimeter of pool. For solid stool maintain free chlorine at 10 PPM and pH between 7.2 and 7.5 for ½ hour then pool may be reopened. For loose stool maintain free chlorine at 10 PPM and pH between 7.2 and 7.5 for 16 hours then pool may be reopened.

Date									
Time of day									
Area of pool									
Cl residual									
pH									
Date									
Time of day									
Area of pool									
Cl residual									
pH									
Date									
Time of day									
Area of pool									
Cl residual									
pH									
Date									
Time of day									
Area of pool									
Cl residual									
pH									
Date									
Time of day									
Area of pool									
Cl residual									
pH									
Date									
Time of day									
Area of pool									
Cl residual									
pH									

Dates and times pool closed \_\_\_\_\_

Dates and times pool reopened \_\_\_\_\_

Record any relevant information (such as reports of illness):

\_\_\_\_\_

Signature of Certified Operator: \_\_\_\_\_